



Karnataka Fire and Emergency Services Department  
Bangalore South Zone, Field Marshall Cariappa Road,  
Ashok Nagar, BANGALORE-560 001  
Phone: 080 – 22971513 / 25585034

No. 2772/ADV/CFD-EAST/BSZ/2021-22

Date: 22-04-2021

To,

The Principal,  
Malthry Vidyanikethan,  
3<sup>rd</sup> Main, NRI Layout, Ramamurthy Nagar  
BANGALORE-560016

Sir,

Sub: Issue of 'Fire Safety Certificate' to : The Principal, Malthry Vidyanikethan, 3<sup>rd</sup> Main,  
NRI Layout, Ramamurthy Nagar, BANGALORE-16

Ref: Your Letter dated 08-04-2021 regarding Issual of fire Safety Compliance Certificate

With reference to the subject above cited, the premises of, Malthry Vidyanikethan, 3<sup>rd</sup> Main,  
NRI Layout, Ramamurthy Nagar, Bangalore-560016 was inspected by District Fire Officer, East Zone,  
Bengaluru on 13/04/2021 with respect to Fire Prevention, Fire fighting and Evacuation measures to be  
complied in the above premises and the DFO [East] has submitted the details as under;

#### ANNEXURE-B

NBC-2016, Part-4, Table 7(11) 3 1.3 Group B Educational Buildings Sub Division B1 & B2  
( These conditions are indicative and not exclusive all relevant provisions related to fire and life safety of  
NBC 2016 are mandatory.)

#### A. Details of the building / premises:-

01. Name and Address of the Applicant : The Principal,  
Malthry Vidyanikethan,  
3<sup>rd</sup> Main, NRI Layout,  
Ramamurthy nagar,  
Bangalore -560016
02. Name and Address of the Premises : The Principal,  
Malthry Vidyanikethan,  
3<sup>rd</sup> Main, NRI Layout,  
Ramamurthy nagar,  
Bangalore -560016
03. Number of Buildings : Adjacent Buildings WingA and WingB
04. Number of Floors : WING A- Cellar +Ground & 2 Upper Floors  
WING B- Ground & 3 Upper Floors



*[Handwritten Signature]*

*H. Sreedee*

PRINCIPAL

Malthry Vidya Nikethan  
NRI Layout, R. M. Nagar,  
BANGALORE - 560 016.

*22/4/21*



05. Floor-wise details of occupancy

- WING A**
- Cellar Floor : A V Room
  - Ground floor : Reception, Principal Room, Office Room, 6 Class Rooms, Server Room, Phy Edn Room, Board Room
  - First Floor : Staff Room, Library, 11 Class rooms
  - Second Floor : 11 classrooms, Chemistry Lab, Staff room.
  - Third Floor : 10 classrooms, Computer Lab, Physics Lab, Math Lab, Staff room.
- WING B**
- Ground Floor : Pre-Primary Activity room, Play area, 3 Classrooms.
  - First Floor : 3 Classrooms, Vice Principal's room.
  - Second Floor : 3 Classrooms, Staff room.
  - Third Floor : Auditorium.

06. Height of the Building : 14.9 mtrs

07 Site Area : 4208 Sq mtrs

08 Built-up Area of each floor :-  
WING A : 3,368.81 Sq mtrs

- Cellar Floor : 199.39 m<sup>2</sup>
- Ground Floor : 603.46 m<sup>2</sup>
- Parking : 188.84 m<sup>2</sup>
- First Floor : 792.37 m<sup>2</sup>
- Second Floor : 792.37 m<sup>2</sup>
- Third Floor : 792.37 m<sup>2</sup>
- Total built up area : 3,368.81 m<sup>2</sup>

WING B : 978.64 Sq mtrs

- Ground : 244.66 m<sup>2</sup>
- First Floor : 244.66 m<sup>2</sup>
- Second Floor : 244.66 m<sup>2</sup>
- Third Floor : 244.66 m<sup>2</sup>
- Total built up area : 978.64 m<sup>2</sup>


09 Total Built up area : Wing A 3,368.81 m<sup>2</sup>  
Wing B 978.64 m<sup>2</sup>

10. Type of Construction

RCC Building

*M. Subramanian*

*22/4/24*



*H. Sreedhar*




**I. Surrounding / Adjacent Properties**

- East : 9 mtrs wide 1<sup>st</sup> Cross
- West : Commercial Building
- North : 4<sup>th</sup> Main Road, NRI Lay Out
- South : 2<sup>nd</sup> Main Road, NRI Lay Out

**B.** On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures are recommended and are considered absolutely essential from fire safety Point of view:-

SL. NO (1)	Details (2)	Existing (3)	Recommendations (4)
01.	Accessibility to the Premises	The premises is accessible from 09.00 mtr wide Road located on North, East & South	Adequate
02.	Number of Entrances	<u>Wing A</u> :- 6.09 mts entrances from 9 mts wide road and another one of 1.52 mts from 9 mts wide road  <u>Wing B</u> :- 2.4 mts entrances from 9 ft wide road and another one 4.84 mts from 9 mts wide road.	Adequate
03.	Number of Stair Cases	<u>Wing A</u> 3 staircases of 5ft, 4ft and 4ft width each <u>Wing B</u> 1 Staircase of 5ft width	Adequate
04.	Open Space Available	East: 2.9 mtr West: 4.0 mtr North: 2.3 mtr South: 1.1 mtr	Adequate Open Ground of 42.38 mtr and 30.48 mtr available in the centre of both wings
05.	Portable extinguishers	07 Nos of ABC type fire extinguishers Each of 02 kgs capacity & 02 Nos of 4.5 kgs Capacity & 3 fire buckets filled with clean dry Sand & water have been Provided.	Adequate  A. One ABC type is provided at celler floor  B. One Water mist Extinguisher of 9 lb capacity Has been kept near each Staircase landing  C. One Mechanical Foam Extinguisher of 9 ltr capacity & one ABC type of Ext. of 6kgs capacity is provided
06.	Escape Routes	Displayed	Escape routes are indicated in the corridor on each floor
07.	Fire Safety Plans	Displayed	A Notice Board is Indicative every floor with Options displayed with Telephone Numbers.

22/4/19  
  
 M. S. S. S.

H. S. S. S.



08. Fire Fighting Training Partially Imparted

40% of the staff has got trained in Basic Fire fighting at R A Mansur Fire and Emergency Services Academy, Bannerughatta Road, Bangalore

09. Fire Precautionary Measures:-

- A. Explosive and flammable materials should not be stored in the store room UPS Room, Electrical Panel Area, Class Rooms, Laboratory & Electrical Panel Premises
- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction
- D. Liquefied Petroleum Gas should not be stored in the building
- E. Doors shall not be kept locked/latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside or outside
- G. As per Hon'ble Supreme court orders all teachers and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on April 14<sup>th</sup> of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'FIRE SAFETY CERTIFICATE' to, The Principal, Maithry Vidyanikethan, 3<sup>rd</sup> Main, NRI Layout, Ramamurthy Nagar subject to conditions and compliance of the above recommendations in Column-3 of Serial-B within 12 months and compliance to the undersigned

This 'FIRE SAFETY CERTIFICATE' is issued for a period of one year from the date of issue & is renewable.

◆ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life Safety will have to complied with, mandatorily

Yours faithfully

*Mahesh*



Chief Fire Officer (Civil)  
Bangalore East Zone, Residential Road,  
BANGALORE-560 001

*San*  
23/4/24

*K. Sreedevi*

PRINCIPAL

Maithry Vidya Nikethan  
NRI Layout, R. M. Nagar,  
BANGALORE - 560 016.